



1636 West North Temple • Suite 220 • Salt Lake City, UT 84116-3156 • 801-533-6071

June 11, 1987

FURNACE DITCH COMPANY c/o Steven Bradshaw 195 North 300 West Beaver, Utah 84713

Gentlemen:

On June 6, 1986, you were sent notice by the state engineer that diversion works and a measuring device must be installed on the Furnace Ditch. These installations must be to the approval of the state engineer. The work was to be done by August 1, 1986 or the state engineer would direct the Beaver River Commissioner to cease the delivery of water to you.

Some efforts were made to install a Parshall flume and a make-shift diversion works. It has been indicated that the flume needs to be adjusted to adequately measure the flows diverted. It is further indicated that the diverting works are inadequate and do not allow for the proper regulation of water to the state engineer's approval.

You are hereby ORDERED to adjust your measuring device to allow for the proper measurement of water and to install a controllable and lockable headgate and diverting works. This work must be done to the approval of the state engineer and be completed within 30 days of this notice or the state engineer will forbid the use of water through the Furnace Ditch until such time as this order is complied with.

If you have any questions, contact Gerald Stoker in Cedar City at 586-4231 or Kent Jones in Salt Lake at 533-6071.

Very truly yours,

Kent L. Jones, P. E.

Directing Engineer, Distribution

for Robert L. Morgan, P. E.

State Engineer

KLJ:cj

cc: Lee Strong, Beaver River Commissioner
Gerald Stoker, P.E., DIVISION OF WATER RIGHTS, Cedar Area Office